MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works, Sector 39.

TEST – REPORT

Not for legal use

Ref. No. & Date	: -	No. H/21-22/331 dated 04.03.2022
Issued to	: -	The Principal, Stepping Stones Senior Secondary School, Sector 37-D, Chandigarh
Quantity of sample	: -	Approximate 1200 ml.
Date of Collection	: -	05.03.2022
Client reference	: -	Sample collected by Laboratory Staff.
Packing of sample	: -	Sample filled in P.P. and Glass Bottle.
Source of sample	:-	from School tap of Stepping Stones Sr. Sec. School, Sector 37-D, Chandigarh

S. No. Examination	Quality Standard	Units	Results
1. Turbidity	<1.0	N.T.U	0.7
2. pH	7.0-8.5	----	7.81
3. Residual Chlorine	0.2 – 0.4	mg/L	0.2
4. Total Alkalinity (as $CaCO_3$)	200	-do-	72
5. Total Hardness (as $CaCO_3$)	200	-do-	64
6. Chlorides (as C1)	200	-do-	04
7. Free & Saline Ammonia	Nil	-do-	Nil
8. Total Dissolved Solids	500	-do-	110
9 M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No.03/2021-22/063742, dated 04.03.2022, Amount Rs.3300/-.

Note:- **Water is fit for drinking.**

Lab. No. MCPHL/22/ 1120
Dated: -07.03.2022

Chemist,
MCPH Laboratory,
Chandigarh

Sub Divisional Engineer,
M.C.P.H. Sub Division No. 2,
Chandigarh

Endst No. MCPHL/22/_____ Dated_____

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh for information please.

Sd/-
Chemist
MCPH Laboratory
Chandigarh

Sd/-
Sub Divisional Engineer,
M.C.P.H. Sub Division No. 2,
Chandigarh